

December 3, 2008

Revised 12/12/2008

FREEDOM PLASTICS INC
PIPE
JON SCHYVINCK
210 SOUTH ARCH ST
PO BOX 1488
JANESVILLE WI 53547-1488

Re: Description: PIPES, PVC
Manufacturer: FREEDOM PLASTICS INC
Product Name: PVC SEWER PIPE-ASTM F679
Model Number(s): 18" PS 46 & PS 115
Product File No: 20080556

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (2) (b) & (c) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2014.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must be labeled with 18" FREEDOM FP1 T-2 12364 PS 46 PVC SEWER PIPE ASTM R-679 LINE#, DATE, SHIFT, J—OR—18' FREEDOM FP1 T-2 12364 PS 115 PVC SEWER PIPE ASTM F-679 LINE#, DATE, SHIFT, J.
- 18" FREEDOM FP1 12364 PS 46 PVC SEWER PIPE ASTM F-679 may only be used as gravity flow Effluent piping, Sanitary building sewer or Storm sewer pipe.
- This product may be installed for the following drain or vent use(s):
 - a. Sanitary drain and vent piping . . gravity flow underground
 - b. Storm drain and vent piping . . . gravity flow underground

This approval supersedes the approval issued on January 16, 2004 under product file number 20030535.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030535.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: Jerry.Thompson@wi.gov